



3701 Plano Parkway, Suite 150 / Plano, Texas 75075  
P: 972-390-8014 – F: 979-705-7611

Page \_\_\_\_ of \_\_\_\_

|  |   |
|--|---|
| <b>Client:</b> St. Michael & All Angels Episcopal Church & School    | <b>Job #:</b> 5411.02   |
| <b>Project:</b> Pre-Phase I (Gym/Locker Rooms/ Mezzanine)            | <b>Lab Job #:</b>   |
| <b>Address:</b> 8011 Douglas Avenue Dallas, TX 75225                 | <b>Rotometer #:</b> Saul 1 <b>Calibration Date:</b> 03-Jul-2023 |
| <b>PPE:</b> Disposable Suit; Safety Glasses; Gloves; Safety Footwear | <b>Microscope ID:</b> CX43RF                                    |

| Sample Number | Sample Location                           | Activity                                      | On Flow Rate LPM | Off Flow Rate LPM | Start Time    | Stop Time     | Total Time Min. | Volume | Fibers/Field | Fibers/CC |
|---------------|---|---|------------------|-------------------|---------------|---------------|-----------------|--------|--------------|-----------|
| D23359        | FB  | -----   | -----            | -----             | -----         | -----         | -----           | -----  | 0.0/100      | <0.005    |
| D23360        | FFB                                       | -----   | -----            | -----             | -----         | -----         | -----           | -----  | 0.0/100      | <0.005    |
| D23361        | IC-Gym                                    | Removal of sheetrock with J/C & final cleanup | 5.22             | 5.22              | 7:39          | 17:23         | 584             | 3,048  | 35.0/100     | 0.006     |
| D23362        | CR-Gym                                    | " "   | 5.22             | 5.22              | 7:47          | 17:33         | 586             | 3,059  | 14.0/100     | <0.005    |
| D23363        | OC-Gym                                    | " "   | 5.22             | 5.22              | 7:48          | 17:34         | 586             | 3,059  | 13.0/100     | <0.005    |
| D23364        | HE-Gym                                    | " "   | 2.06             | 2.06              | 7:59          | 17:53         | 594             | 1,224  | 3.5/100      | <0.005    |
| D23365        | OWA-1 School Halway West                  | Air Quality Monitor                           | 2.06             | 2.06              | 10/11/23 7:18 | 10/12/23 6:42 | 1404            | 2,211  | 8.0/100      | <0.005    |
| D23366        | OWA-2 School Hallway Center               | " "   | 2.06             | 2.06              | 10/11/23 7:21 | 10/12/23 6:43 | 1402            | 2,208  | 7.5/100      | <0.005    |
| D23367        | OWA-3 School Hallway East                 | " "   | 2.06             | 2.06              | 10/11/23 7:27 | 10/12/23 6:47 | 1400            | 2,205  | 8.0/100      | <0.005    |
| D23368        | Construction barrier at stairs to the Gym | Removal of sheetrock with J/C & final cleanup | 2.06             | 2.06              | 7:10          | 16:42         | 572             | 1,178  | 5.0/100      | <0.005    |

| GENERAL INFORMATION         | SAMPLE ACTIVITY                   |                                | SAMPLE LOCATION                                 |                             | CHAIN OF CUSTODY              |                   |
|-----------------------------|-----------------------------------|--------------------------------|---|-----------------------------|-------------------------------|-------------------|
| FIELD AREA = 0.00785 sq. mm | BL = Baseline (1,250 L)           | PR = Prep                      | IC = Inside Containment                         | FIELD AREA = 0.00785 sq. mm | Collected By: C. Saul Nazario | Date: 11-Oct-2023 |
| LPM=Liters Per Minute       | AB = Abatement (include material) | GB = Glovebag                  | OC = Outside Containment                        | LPM=Liters Per Minute       | Submitted By:                 | Date:             |
| FILTER AREA = 385 sq. mm    | CL = Cleaning                     | FC = Final Clearance (1,250 L) | CR = Decon Clean Room                           | FILTER AREA = 385 sq. mm    | Received By:                  | Date:             |
| OLM = Overloaded Mixed      | BK = Blank                        | BO = Bag Out                   | IWA= Inside Work Area<br>OWA= Outside Work Area | OLM = Overloaded Mixed      | Analyzed By: C. Saul Nazario  | Date: 12-Oct-2023 |

NIOSH 7400 Method - "A" Counting Rules

Fibers/CC=Fibers Cubic Centimeter based on the following equation for a 25 mm filter cassette:

LOQ=Limit of Quantitation based on 10 fibers/100 fields

$$\frac{(\text{fibers/field}) \times (385 \text{ mm}^2 / 1 \text{ filter}) \times (1 \text{ field} / 0.00785 \text{ mm}^2)}{\text{flowrate in liters} \times \text{sample time in minutes} \times (1000 \text{ cc} / 1 \text{ liter})}$$